

CLIENT: STABILIT AMERICA, INC
285 Industrial Dr.
Moscow, TN 38057

Test Report No: TJ3605	Date: March 4, 2016
-------------------------------	----------------------------

SAMPLE ID: The client identified the following test material as “FCF/MFCF 0.090 F-5038”

SAMPLING DETAIL: Test samples were submitted to the laboratory directly by the client. No special sampling conditions or sample preparation were observed by QAI.

DATE OF RECEIPT: Samples were received at QAI facilities on February 27, 2016

TESTING PERIOD: March 2, 2016


AUTHORIZATION: Signed work order FB-2016-021101

TEST REQUESTED: Perform standard flame spread and smoke density developed classification tests on the sample supplied by the Client in accordance with CAN/ULC S102-10, “Method of Test for Surface Burning Characteristics of Building Materials and Assemblies”.

TEST RESULTS:	<u>Flame Spread</u>	<u>Smoke Developed</u>
	140	135

Detailed test results are presented in the subsequent pages of this report

Prepared By



Jeff Foster
Fire Test Technician

**Signed for and on behalf of
QAI Laboratories, Inc.**



J. Brian McDonald
Operations Manager